

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 45-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – Simplex Time Recorder Co., 100 Simplex Drive, Westminister, MA 01441.

Trade Name – Ansul Incorporated, Simplex.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – Reference Standard RS-17.

Test – UL 864, UL 1076.

Laboratory – Underwriters Laboratories, Inc.

Test Reports – UL Multiple listing files: S6567, issued October 16, 2002, revised November 26, 2002.

Description – The Model Triton RP is a four Zone Local Fire Alarm Control Panel suitable for Releasing Device Service. Rated 120 to 240 Volts AC power input. Red Enclosure. Pyro Chem alarm control unit is multiple listed with Simplex's fire alarm control unit as follows:

1. The basic listing for the following products is found in the Simplex UL file S771, Volume 52, and MEA 35-93-E Vol. XV.

<u>Ansul Model</u>	<u>Ansul P/N</u>	<u>Simplex Model</u>
Triton RP	551450	4004-9302

Pursuant to "Promulgation of the Rules relating to Materials and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated November 6, 2003, F.P. Index #0302037A.

Recommendation- That the above units be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested an accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

January 14, 2004

Examined by

[Handwritten Signature]